

HB4792



103RD GENERAL ASSEMBLY

State of Illinois

2023 and 2024

HB4792

Introduced 2/6/2024, by Rep. Dave Vella

SYNOPSIS AS INTRODUCED:

415 ILCS 30/9.3 new

Amends the Illinois Water Well Construction Code. Provides that the minimum lateral setback distance between a closed-loop well and a storm sewer, sanitary sewer, combined sewer, or any other potential source of contamination is 5 feet. Specifies that setbacks from footing drains and pits, crawl spaces, and basements do not apply to closed-loop wells.

LRB103 38824 BDA 68961 b

A BILL FOR

1 AN ACT concerning safety.

2 **Be it enacted by the People of the State of Illinois,**
3 **represented in the General Assembly:**

4 Section 5. The Illinois Water Well Construction Code is
5 amended by adding Section 9.3 as follows:

6 (415 ILCS 30/9.3 new)

7 Sec. 9.3. Closed-loop well setbacks.

8 (a) The minimum lateral setback distance between a
9 closed-loop well and a storm sewer, sanitary sewer, combined
10 sewer, or any other potential source of contamination is 5
11 feet.

12 (b) Setbacks from footing drains and pits, crawl spaces,
13 and basements do not apply to closed-loop wells.